

ENGLISH



# **Energy Meter Manual**

EM24 RS485

rev 07 - 09/2024 This manual is also available in HTML5

# **Table of Contents**

1. Introduction	. 1
1.1. Features	. 1
2. Installation and configuration	. 2
2.1. AC wiring	. 2
2.1.1. Configuration options	
2.1.2. System examples	
2.2. Connection to a GX device	
2.2.1. Wired connection to a GX device	
2.2.2. Zigbee connection to a GX device	
2.3. GX device configuration	
2.4. Multiple Energy Meters in one system	. 8
2.4.1. Changing the modbus address	. 9
3. Information on multiple Zigbee pairs	10
3.1. Multiple Zigbee pairs	10
4. FAQ	11



# 1. Introduction

The Victron EM24 RS485 is a standard device to measure the power and energy of a 3-phase application. Its data will be displayed on a GX device and our VRM portal.

# 1.1. Features

The EM24 RS485 can be configured for four different roles in a GX device such as the Cerbo GX:

- 1. As a Grid meter and used as control input for an ESS System.
- 2. To measure the output of a PV Inverter.
- 3. To measure the output of a AC Genset.
- 4. As an AC meter to measure a dedicated AC load circuit.

It offers two options for connection to a GX device:

- 1. A wired connection, either by using the RS485 to USB interface with 1.8m or 5m cable length.
- 2. A wireless connection via our Zigbee to USB and Zigbee to RS485 converter.



# 2. Installation and configuration

# 2.1. AC wiring


# 2.1.1. Configuration options

The configuration option of either Grid Meter, PV Inverter, Generator or AC Meter is set in the GX device. For details on GX device configuration see the GX device configuration [6] chapter. This selection will affect how the system should be wired and how the information received from the meter is displayed on the screen.

See the below diagrams for the different wiring options. Note that wherever the word "Fuse" appears in the diagrams, a 315 mA fuse should be used, if required by local law.

## 2.1.2. System examples

## Example diagrams




EM24 3-phase wiring

When used to measure a PV Inverter, terminals 1, 4 and 7 should face the PV inverter to ensure correct direction of current and power.

9



Single-phase, single function



EM24 connected as a single-phase, single function grid meter

Note the jumper between terminals 1 and 4. You do not need this connection if you have the version AV2 of the sensor.

The diagrams show the wiring when used as a grid meter.

To measure a single-phase PV inverter in a 3-phase system, connect all 3 phases to the grid phasing terminals (3, 6 and 9). Now you can chose on which phase you want the PV inverter by connecting the L1 line of the PV inverter to terminal 1, 4 or 7.

### Single-phase, dual function

The EM24 RS485 meter supports dual function, but using it in this way is not recommended. This is because energy accounting is done over the total of all phases, and the meter only has a single reverse energy counter and cannot accurately account for grid feed-in while also measuring consumption.

Therefore, in systems that feed significant amounts of energy into the grid, the EM24 RS485 should not be used in dual function mode. If you need dual function, we recommend using either the EM540 or two single-phase meters.

## Front selector

Change the front selector so it is not in the locked state. This allows it to be automatically configured by the GX Device. The front selector is located next to the display as indicated in the image above.



# 2.2. Connection to a GX device

## 2.2.1. Wired connection to a GX device


Connect the EM24 RS485 to the GX device using the RS485 to USB interface.

The RS485 to USB interface cable between the GX device and the Energy Meter can be extended up to 100 meters; make sure that the extensions of the Data+ (orange) and Data- (yellow) wires form a twisted pair.

The table below shows the colors of the wires and their connection to the terminals of the EM24 RS485, as well as the colors to be used for a CAT5 extension cable.

RS485 to USB	RS485 Signal	EM24 RS485 terminal number	Suggested wire color CAT5 extension cable
Orange	Data +	42	Orange
Yellow	Data -	41	Orange/White
Black	GND	43	Brown

The red, green and brown wire coming out of the RS485 to USB cable are not used. Cut them off or bend them back and isolate them.



EM24 wired connection to a Cerbo GX using the RS485 to USB interface

To ensure signal integrity and robust operation, particularly ensure that:

- The extension cabling complies with the minimum cross-sectional area specifications in the RS485 to USB interface data sheet.
- The extension cabling has appropriate shielding and twisted pair cores.
- The original cable attached to the Victron RS485 USB interface is reduced to a maximum length of 20cm for installations where the total cable length exceeds 10m or where installation/site specific interference occurs in this case, a suitable/quality cable should be used for the entire cable length and not only for the extension length.
- · Cabling is installed separated/away from the main DC or AC power cabling.
- · All wiring is properly terminated (including unused wires) and properly isolated from weather/water ingress.
- RS485 networks are traditionally terminated at both ends with 120Ω terminators. This is not required if the cable length is short and you are using the Victron supplied RS485 to USB lengths, but may be required if the cable length is modified.
- · For detailed wiring/installation notes and specifications refer to the Victron RS485 to USB interface cable 'Datasheet'.

# 2.2.2. Zigbee connection to a GX device

The EM24 RS485 can also be wirelessly connected to a GX device via our Zigbee to USB converter & Zigbee to RS485.

The Zigbee to USB converter is connected to the GX device and the Zigbee to RS485 converter is connected to the EM24 RS485.

1. Connect the Zigbee to USB converter to the GX device using the supplied USB cable.


A few seconds after connecting, the active LED should be on and the TX/RX LED should be blinking (the converter takes its power from the GX device, so the GX device needs to be switched on as well).

2. Connect the Zigbee to RS485 converter to the EM24 RS485 energy meter according to the table below:

Zigbee to RS485	EM24 RS485 terminal number	Color
GND	43	Black
А	42	Orange
В	41	Yellow

In case you have several Zigbee devices installed, make sure only one Zigbee device is powered up right now: the Zigbee to USB converter connected to the GX device. Power down all others. If you don't do this, the Zigbee to RS485 converter may be connected permanently to another Zigbee device.

3. Connect the 12V DC power supply to the Zigbee to RS485 converter. When the power is switched on, check the LEDs again.



Energy Meter wireless Zigbee connection to a Cerbo GX

## Note on old and new Zigbee converters

Please note that there is a new Zigbee converter available now, that is **not** backwards compatible with the old converters. See table below for old versus new part numbers. If you have a non compatible set, please ask your supplier for a correct version.

old/new	Victron part number	Zigbee to RS485 converter part number
old	ASS300400100	DRF2619C
old	ASS300400100	DRF2618A
new	ASS300420100	DRF2659C
new	ASS300420200	DRF2658C

## Note on GX firmware versions

For the new type Zigbee converters, Venus OS v2.54 is the minimum required software version.



# 2.3. GX device configuration

After proper connection and powering up, the meter(s) will be visible on the GX device in the Settings  $\rightarrow$  Energy meters menu:

<	Energy meters	হ্ন 12:13	<	Energy meters	হি 14
73069V		>	BT2590057001	3	
			BU1400063001	3	
<u> 네</u> Pages		<b>⊟</b> Menu	<u>ய</u> Page	S	<b>≡</b> Menu
ngle Energy Mete	er in the Energy meters n	nenu	Two Energy Met	ers in the Energy meters	menu

After selecting an Energy Meter, you have to set the Role and Phase type. Press the space bar or right click to get to the Phase type and Role menu:

<	273069V	র্ল 12:13		<	BT25900570013	হ্ন 14:12
Role		AC meter		Role		Grid meter
Phase type		Single phase	1	Phase type		Multi phase
<u></u> 네 Pages		<b>⊟</b> Menu		<u>네</u> Pages		<b>≡</b> Menu
<sup>-</sup> or the ET112 only S	ingle phase option is	displayed	D	epending on the a	pplication, the role is	set here

Select either Role or Phase type and press the space bar to make changes:

<	Role	奈 14:14	<	Phase type	奈 14:12
Grid meter		•	Single phase		0
PV inverter		0	Multi phase		Θ
Generator		0			
AC load		0			
$\bigotimes$		$\bigotimes$	$\bigotimes$		$\bigotimes$
Select the Role acc	cording to the applicat	ion	Selection menu for	Single and Multi phase	type

Single-phase, single function and single-phase, dual function mode setup:



After all settings have been made, the Energy Meter now appears with the relevant data in the device list of the GX device:

	Device List	4	<u> </u> 72:	18
AC load			72W	>
lueSolar Charger MPP	T 150/35 rev2		77W	>
lur		22°C	52%	>
ithium Smart 330Ah	65%	13.33V	-0.4A	>
MultiPlus 12/1600/70-16	5	Inv	verting	>
PSC IP43 12 50HQ200	7P5YSI		Off	>
<u>ااا</u> Pages	~	<b>≣</b> Mer	าน	

Right-click or press the spacebar to get to the Energy Meter overview with all relevant data on energy consumption and its generation in all phases. At the bottom of the menu, the role of the Energy Meter can be set via the Setup menu. The data used for communication can be read out via the Device menu. You can also set up a custom name for the Energy Meter there:

<	Grid m	eter	奈 14:13	<	Grid meter	হি 14
Error Code			No error (0)	Energy L1		1843.8kV
AC Phase L1	237V	-1.8A	-388W	Energy L2		2428.1kW
AC Phase L2	237V	-1.9A	-427W	Energy L3		2251.0kW
AC Phase L3	238V	-1.6A	-338W	Phase Sequence	e	L1-L2-
AC Totals		-5.4A	-1153W	Setup		
AC IOLAIS			5606.4kWh	Device		
<u>ااا</u> Pages	~		<b>≡</b> Menu	<u>ااا</u> Page	s ^	<b>≡</b> Menu
etailed overview pa	age of a 3-p	ohase Grid r	neter	Always be inform	ned about all details, to	the second

<	Device	奈 14:14
Connected		Yes
Connection		/dev/ttyUSB0
Product		Grid meter
Name		
Product ID		b002
Firmware version		3
<u> 네</u> Pages	~	<b>≡</b> Menu
Custom name configu	ration	

# 2.4. Multiple Energy Meters in one system

To connect multiple Energy Meters, wire each meter to a separate RS485 to USB interface, which are then each plugged into a separate USB socket on the GX device.

There are 3 options to connect multiple Energy Meters:

- Each wired to a separate RS485 to USB interface, which are then each plugged into a separate USB socket on the GX device.
- Two Energy Meters wired on to one RS485 to USB interface. In this case the modbus address of the additional meter needs to be changed, so each is unique. See next chapter Changing the modbus address [9].
- Wireless connection: the additional meter is connected to an additional Zigbee to RS485 converter. There is then no second Zigbee to USB converter required. It is then necessary to change the modbus address of one of the AC sensors. See chapter Changing the modbus address [9].

Besides adding an additional sensor, in a single-phase installation it is also possible to use the unused second phase to measure the power of the PV inverter. See the AC Wiring chapter [2] in this manual.



# 2.4.1. Changing the modbus address

- 1. Press the joystick down until the display shows 'Pass'. The joystick on the right side on the display, above the front selector).
- 2. Press the joystick down again and release immediately.
- 3. Press the joystick right several times until 'Address' appears. Press the joystick down. Now you can adjust the address by pressing the joystick up and down. Set it to 2.
- 4. Press down again. 'Baudrate' appears.
- 5. Press down again twice. 'Address' appears again.
- 6. Press right until 'End' appears.
- 7. Press down. The display now shows measurements again.



Only one extra Energy Meter can be added: the system works only with address 1 (the default) and 2.



# 3. Information on multiple Zigbee pairs

# 3.1. Multiple Zigbee pairs

Running multiple Zigbee pairs is rather unusual and not recommended due to its complexity in configuration via the Chinese language configuration software. However, for those who still want to try, we show a possible solution.

The following is only valid for the new Zigbee converters with part number DRF2658 and DRF2659. For older units there is no software support anymore.

To run multiple pairs, the PAN-Id needs to be different, otherwise they interfere with one another. Basic information about where to obtain the software and how to reconfigure this:

- 1. Go to http://www.dtkcn.com/
- 2. Use the translation feature of your browser if you don't read Chinese, then download the "DTK wireless module configuration software".
- 3. The installation is in Chinese, but can be installed by clicking the equivalent "Next" button repeatedly. The software itself has an English translation.
- 4. You need to wire an RS485 to USB interface to the RS485 Zigbee module if you need to reconfigure it. The alternative is to reconfigure the USB unit (the coordinator) BEFORE you turn on the RS485 side (the router). The router will always join the coordinator and get its initial settings at startup.
- 5. Each pair must have a different PAN-Id.



It is unusual to have multiple Zigbee links. Using an Energy meter via Ethernet (possibly with a Wi-Fi link) is the more reliable option in any case.



# 4. FAQ

#### Q1: Can I combine three ET112s for a 3-phase system?

No. Use a real 3-phase meter.

#### Q2: Can I use other meters, for example from other brands?

No.

#### Q3: I already have a Fronius SmartGrid meter, can I use that?

No.

#### Q4: What are the differences between the various 3-phase meters?

- EM540 REL200100100 Carlo Gavazzi EM540DINAV23XS1X
- ET112 REL300100000 Carlo Gavazzi ET112-DIN.AV01.X.S1.X
- ET340 REL300300000 Carlo Gavazzi ET340-DIN.AV23.X.S1.X

#### Differences:

- The ET meters have no display. The only thing they have is an LED, which blinks in case of active communication.
- The ET meters have two RJ45 sockets, but they are not used with the Victron RS485 to USB interface. Note the possible confusion because of yet another RJ45 socket in the Victron world though. Don't mix that with VE.Bus, VE.Can or VE.net. Besides the RJ45 sockets, the meters still also have screw terminals access below the sockets for the RS485 wiring, which is how we advise to connect a meter to the RS485 to USB interface and then a GX device.
- Since there is no display, the modbus address can no longer be changed on the meter. Combining multiple of those meters on one RS485 network is therefore not supported by Victron. You are advised to use multiple RS485 to USB interfaces.

#### 3-phase meter only:

• Measuring energy from single-phase PV Inverter on the second phase of a 3-phase meter actually works.

#### Q5: Will you keep shipping both 3-phase meters? (ET340 & EM540)

Yes. There are still situations suitable for each. See Q8.

#### Q6: Can I buy those meters directly from Carlo Gavazzi instead of from you?

Yes. That is also why we make no secret of the CG part numbers.

## Q7: I want to use Current Transformers (CTs), is that possible?

Yes. You can buy a CG EM24DINAV53DISX or a CG EM530DINAV53XS1X directly from Carlo Gavazzi or one of their distributors. Even though Victron does not stock that type of meter, we do support it in our software.

#### Q8: What's the difference between ET340 and EM540 in 3-phase systems?

These meters have a different way of calculating the total of energy imported and exported.

In the ET340, the energy imported and exported is counted at each individual phase and then the Total is provided from the sum of those values.

In the EM540, the energy imported and exported is counted as a total power, with net differential readings from each phase cancelling each other out.

Which Energy Meter is most suitable depends on the measuring configuration in your country. It is most common in Austria and Germany for example to only be billed for the total in a 3-phase system. So it is more accurate to use an EM540 to match the billing.

So if you are exporting from one phase and importing from another phase after the energy meter, but before the billing meter, then you will not be charged for this, and the meter should not count it as an import and an export.

This is also how Victron's phase compensation feature works, to make the most of the cost savings for an ESS system when there is a differential in generation and load across different phases.

#### Q9: Can I use an isolated USB-RS485 interface?

Yes. The interfaces we sell are non isolated; suitable for most use cases.

In case an isolated one is needed; purchase it directly from Hjelmslund Electronics.

· USB485-STIXL : Isolated USB to RS485 converter

# Q10: Can I use Victron Energy Meters instead of a Victron Inverter/Charger to make use of a GX device (e.g. Cerbo GX), VRM and other features?

Energy Meters are intended to supplement a Victron Inverter/Charger in the system. Energy Meters are currently limited in their potential applications. Each Energy Meter is only intended to provide a specific piece of additional information - total loads on AC input and grid import/export, or AC PV inverter and AC generator production without network communications.

However, it is perfectly possible to initially use just a GX device together with an Energy Meter to determine and record the consumption, for example of houses/buildings, heating systems with heat pumps, ventilating and air conditioning or production facilities. Afterwards, the collected data can be evaluated and a decision can be made about the dimensioning of the required Victron inverter/charger(s), the solar system and the type, size and number of batteries.

With GX device firmware version 2.80 and later, they can also be used for other purposes e.g. to measure specific, arbitrary AC loads or circuits for example. But this should not be considered a replacement to having a Victron Inverter/Charger. Attempting to use other brand battery inverters and trying to substitute their lack of data connectivity to the GX device by using Energy Meters will not work as expected.

